

# 2025 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 5020009

Harmar Water Authority

*Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it or speak with someone who understands it.)*

## WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Joe McCollum, Operations Administrator, at 724-274-7383. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of every month at 3:30 pm at the Authority office located at 200 Pearl Ave. Cheswick, PA.

## SOURCE OF WATER:

The source of our water is three wells that draw from the alluvial deposits in the Allegheny Valley Aquifer, a glacial deposit of sand and gravel along the present-day banks of the Allegheny River.

The PA Department of Environmental Protection (PADEP), Allegheny County, has conducted a Source Water Assessment and Protection (SWAP) study of Harmar Water Authority's aquifer system in 2003. The assessment has identified that the aquifer is susceptible to contamination from rail, river and road traffic along Route 28, Harmar Twp. Other sources of possible contamination are identified by activity from population growth, changes in industry and land use. The SWAP was updated in 2024 and approved by the PADEP. Information regarding the report is available at the Authority Office at 724-274-8028.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

## DEFINITIONS AND ABBREVIATIONS:

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Residual Disinfectant Level (MinRDL)** - The minimum level of residual disinfectant required at the entry point to the distribution system.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**pCi/L** - picocuries per liter (a measure of radioactivity)

**ppb** - parts per billion, or micrograms per liter ( $\mu\text{g/L}$ )

**ppm** - parts per million, or milligrams per liter (mg/L)

**ppt (ng/l)** = parts per trillion, or nanograms per liter

## MONITORING YOUR WATER:

Harmar Water Authority routinely monitors contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1, 2025 to December 31, 2025. The State allows us to monitor some contaminants less than once per year because the concentration of these contaminants does not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table

**DETECTED SAMPLE RESULTS:**

| Chemical Contaminant                | MCL     | MCLG     | Highest Level Detected | Range of Detections | Units | Date Sampled | Violation Y/N | Sources of Contamination   |
|-------------------------------------|---------|----------|------------------------|---------------------|-------|--------------|---------------|--|
| Barium                              | 2       | 2        | 0.0674                 | 0.0542-0.0674       | ppm   | 2024         | N             | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits   |
| Chromium                            | 100     | 100      | 2.56                   | 0.00-2.56           | ppb   | 2024         | N             | Discharge from steel and pulp mills; Erosion of natural deposits                             |
| Fluoride                            | 2(1)    | 2(1)     | 0.23                   | 0.18-0.23           | ppm   | 2024         | N             | Water additive which promotes strong teeth.  |
| Nitrate                             | 10      | 10       | 1.12                   | 0.67-1.12           | ppm   | 8/5/2025     | N             | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. |
| Uranium                             | 30      | 0        | 1.21                   | (2)                 | ppb   | 2/6/2024     | N             | Erosion of natural deposits  |
| Chlorine (Distribution)             | MRDL =4 | MRDLG =4 | 1.02 (May 2025)        | 0.49-1.02           | ppm   | 2025         | N             | Water additive used to control microbes.   |
| TTHMs [Total trihalomethanes]       | 80      | N/A      | 2.5                    | (2)                 | ppb   | 9/10/2025    | N             | By-product of drinking water chlorination  |
| Perfluorooctanoic Acid (PFOA)       | 14      | 8        | 0.815                  | 0.00-1.67           | ppt   | 2025         | N             | Discharge from manufacturing facilities and runoff from land use activities.                 |
| Perfluorooctanesulfonic acid (PFOS) | 18      | 14       | 1.77                   | 1.41-2.67           | ppt   | 2025         | N             | Discharge from manufacturing facilities and runoff from land use activities.                 |

**Entry Point Disinfectant Residual**

| Contaminant     | Minimum Disinfectant Residual | Lowest Level Detected | Range of Detections | Units | Lowest Sample Date | Violation Y/N | Sources of Contamination                 |
|-----------------|-------------------------------|-----------------------|---------------------|-------|--------------------|---------------|--|
| Chlorine (2025) | 0.50                          | 0.65                  | 0.65-1.95           | ppm   | 1/2/25             | N             | Water additive used to control microbes. |

(1) EPA's MCL for fluoride is four ppm. However, Pennsylvania has set a lower MCL to better protect human health.

(2) only one sample is required.

| <b>Lead and Copper 2025</b> |                   |      |                                   |                               |       |                                    |               |  |
|-----------------------------|-------------------|------|-----------------------------------|-------------------------------|-------|------------------------------------|---------------|--|
| Contaminant                 | Action Level (AL) | MCLG | 90 <sup>th</sup> Percentile Value | Range of Tap Sampling Results | Units | # of Sites Above AL of Total Sites | Violation Y/N | Sources of Contamination   |
| Lead                        | 15                | 0    | 3.05                              | 0.00-3.05                     | ppb   | 0 out of 10                        | N             | Corrosion of household plumbing systems; Erosion of natural deposits                                   |
| Copper                      | 1.3               | 1.3  | 1.02                              | 0.00-1.02                     | ppm   | 0 out of 10                        | N             | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |

**Lead:** *Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Harmar Water Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Harmar Water Authority at 724-274-7383. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).*

The Harmar Water Authority prepared a service line inventory that includes the type of material contained in each service line in our distribution system. This inventory can be accessed by contacting our office at 724-274-7383.

**Violations:** As you can see from the table, our system had no MCL violations. We're proud that your drinking water meets or exceeds all Federal and State requirements.

#### **EDUCATIONAL INFORMATION:**

All sources of drinking water are subject to potential contaminants that are naturally occurring or man-made. These contaminants may be microbes, organic or inorganic chemicals or radioactive materials. Drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, EPA and DEP prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Thank you for allowing us to continue providing your family with clean, quality water this year. To maintain a dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected in rate structure adjustments. Thank you for understanding.

We at Harmar Water Authority work around the clock to provide top quality water for every tap. We ask that all our customers help us to protect our water sources, which are the heart of our community, our way of life and our children's future.